

STAIRS AND STAIRWAYS

- Are standard stair rails or handrails on all stairways having four or more risers?

Action to be Taken

Assigned To:

- Are all stairways at least 22 inches wide?

Action to be Taken

Assigned To:

- Do stairs have landing platforms not less than 30 inches in the direction of travel and extend 22 inches in width at every 12 feet or less of vertical rise?

Action to be Taken

Assigned To:

- Do stairs angle no more than 50 and no less than 30 degrees?

Action to be Taken

Assigned To:

- Are stairs of hollow-pan type treads and landings filled to the top edge of the pan with solid material?

Action to be Taken

Assigned To:

- Are step risers on stairs uniform top to bottom?

Action to be Taken

Assigned To:

- Are steps on stairs and stairways designed or provided with a surface that renders them slip resistant?

Action to be Taken

Assigned To:

- Are stairway handrails located between 30 and 34 inches above the leading edge of stair treads?

Action to be Taken

Assigned To:

- Do stairway handrails have at least 3 inches of clearance between the handrails and the wall or surface they are mounted on?

Action to be Taken

Assigned To:

Stairs and Stairways

- Where doors or gates open directly on a stairway, is there a platform provided so the swing of the door does not reduce the width of the platform to less than 21 inches?

Action to be Taken

Assigned To:

- Are stairway handrails capable of withstanding a load of 200 pounds, applied in any direction at any point on the rail?

Action to be Taken

Assigned To:

- Where stairs or stairways exit directly into any area where vehicles may be operated, are adequate barriers and warning provided to prevent employees from stepping into the path of traffic?

Action to be Taken

Assigned To:

- Do stairway landings have a dimension measured in the direction of travel, at least equal to the width of the stairway?

Action to be Taken

Assigned To:

- Is the vertical distance between stairway landings limited to 12 feet or less?

Action to be Taken

Assigned To:
